



Rue du Ruisseau – Parc d'activités de Chesnes
38070 SAINT-QUENTIN-FALLAVIER - France

Tel. +33 4 74 94 86 50
Fax +33 4 74 94 86 59

CONFORMITY CERTIFICATE

ITEM : Brass check valve **307**

Construction : Body : brass

Use : Max. temperature 100°C. Max. pressure 16/10/8 bar.
Adapted to all common fluids for fuel site including gasoline and diesel oil.

Concerned by article 3, 3 from 97/23/CE directive.

SAINT QUENTIN-FALLAVIER
09 February 2011

THERMADOR INTERNATIONAL
P.A. DE CHESNES
107 rue du Ruisseau
38070 ST QUENTIN FALLAVIER Cedex
Tél. : +33 474 948 650 Fax +33 474 948 659